

Service Meter Testing FY 2015

	Percent Registered		
	Low Flow	Medium Flow	High Flow
Meter Number	0.25 GPM	2 GPM	10 GPM
1	95%	97%	96%
2	100%	99%	99%
3	99%	99%	99%
4	95%	95%	95%
5	0%	100%	100%
Average	78%	98%	98%

Service Meter Testing FY 2016

	Percent Registered		
	Low Flow	Medium Flow	High Flow
5/8" Meter Number	0.25 GPM	2 GPM	10 GPM
1	0%	5%	62%
1" Meter Number	0.75 GPM	6 GPM	40 GPM
2	93%	95%	100%
3	96%	101%	100%
4	91%	97%	99%
Average	70%	75%	90%