

## REPORTED INCIDENTS

**Date:** April 10, 2018

**Location:** 303 Hill Lane, Trophy Club, Texas

**Occurrence:** Sanitary sewer overflow from a manhole at 303 Hill Lane was reported at 8:45 AM. The overflow was stopped by 9:15 AM

**Cause and Effect:** Rags were found clogging the main. An estimated 190 gallons was spilled.



**Corrective Actions:** Ran a rod through the main to clear the blockage.

**Reporting:** Reported incident to TCEQ verbally on 4/10/2018 and in writing within 5 days.