

**DMR Copy of Record**

|                    |                         |                    |   |
|--------------------|-------------------------|--------------------|---|
| <b>Permit</b>      |                         |                    |   |
| Permit #:          | TX0055735               | Permittee:         | TROPHY CLUB MUD 1   |
| Major:             | Yes                     | Permittee Address: | 100 MUNICIPAL DRIVE<br>TROPHY CLUB, TX 76262                  |
| Permitted Feature: | 001<br>External Outfall | Discharge:         | 001-A<br>DOMESTIC FACILITY - 001                              |
| Facility:          |                         | Facility Location: | TROPHY CLUB MUD 1<br>100 MUNICIPAL DRIVE<br>ROANOKE, TX 76262 |

|                                  |                           |               |          |
|----------------------------------|---------------------------|---------------|----------|
| <b>Report Dates &amp; Status</b> |                           |               |          |
| Monitoring Period:               | From 05/01/18 to 05/31/18 | DMR Due Date: | 06/20/18 |
| Status:                          | NetDMR Validated          |               |          |

**Considerations for Form Completion**  
SEE PAGE 2 OF PERMIT FOR ADDITIONAL REPORTING REQUIREMENTS.

|                                    |         |            |                |
|------------------------------------|---------|------------|----------------|
| <b>Principal Executive Officer</b> |         |            |                |
| First Name:                        | Mike    | Title:     | Superintendent |
| Last Name:                         | McMahon | Telephone: | 682-831-4689   |

**No Data Indicator (NODI)**  
Form NODI: --

| Code  | Parameter Name                           | Monitoring Location                | Season # | Param. NODI | Quantity or Loading |         |                  |         |                  | Quality or Concentration |         |                  |         |                  | # of Ex.       | Frequency of Analysis    | Sample Type              |                          |           |
|-------|--|------------------------------------|----------|-------------|---------------------|---------|------------------|---------|------------------|--------------------------|---------|------------------|---------|------------------|----------------|--------------------------|--------------------------|--------------------------|-----------|
|       |  |                                    |          |             | Qualifier 1         | Value 1 | Qualifier 2      | Value 2 | Units            | Qualifier 1              | Value 1 | Qualifier 2      | Value 2 | Qualifier 3      |                |                          |                          | Value 3                  | Units     |
| 00300 | Oxygen, dissolved [DO]                   | 1 - Effluent Gross                 | 0        | --          | Sample              | =       | 7                |         |                  |                          | =       | 7                |         |                  |                |                          | 19 - mg/L                | 02/07 - Twice Every Week | GR - GRAB |
|       |  |                                    |          |             | Permit Req.         | >=      | 6 MO MIN         |         |                  |                          |         |                  |         |                  |                | 19 - mg/L                | 02/07 - Twice Every Week | GR - GRAB                |           |
|       |  |                                    |          |             | Value NODI          |         |                  |         |                  |                          |         |                  |         |                  |                |                          |                          |                          |           |
| 00400 | pH                                       | 1 - Effluent Gross                 | 0        | --          | Sample              | =       | 7.3              |         |                  |                          | =       | 7.58             |         |                  |                | 12 - SU                  | 01/07 - Weekly           | GR - GRAB                |           |
|       |  |                                    |          |             | Permit Req.         | >=      | 6 MINIMUM        |         |                  |                          | <=      | 9 MAXIMUM        |         |                  | 12 - SU        | 01/07 - Weekly           | GR - GRAB                |                          |           |
|       |  |                                    |          |             | Value NODI          |         |                  |         |                  |                          |         |                  |         |                  |                |                          |                          |                          |           |
| 00530 | Solids, total suspended                  | 1 - Effluent Gross                 | 0        | --          | Sample              | =       | 8.5              |         | 26 - lb/d        |                          | =       | 1.2              |         | =                | 1.4            | 19 - mg/L                | 02/07 - Twice Every Week | CP - COMPOS              |           |
|       |  |                                    |          |             | Permit Req.         | <=      | 175 DAILY AV     |         | 26 - lb/d        |                          | <=      | 12 DAILY AV      |         | <=               | 40 DAILY MX    | 19 - mg/L                | 02/07 - Twice Every Week | CP - COMPOS              |           |
|       |  |                                    |          |             | Value NODI          |         |                  |         |                  |                          |         |                  |         |                  |                |                          |                          |                          |           |
| 00610 | Nitrogen, ammonia total [as N]           | 1 - Effluent Gross                 | 0        | --          | Sample              | =       | 2.06             |         | 26 - lb/d        |                          | =       | 0.4              |         | =                | 0.48           | 19 - mg/L                | 02/07 - Twice Every Week | CP - COMPOS              |           |
|       |  |                                    |          |             | Permit Req.         | <=      | 15 DAILY AV      |         | 26 - lb/d        |                          | <=      | 1 DAILY AV       |         | <=               | 10 DAILY MX    | 19 - mg/L                | 02/07 - Twice Every Week | CP - COMPOS              |           |
|       |  |                                    |          |             | Value NODI          |         |                  |         |                  |                          |         |                  |         |                  |                |                          |                          |                          |           |
| 00620 | Nitrogen, nitrate total [as N]           | 1 - Effluent Gross                 | 0        | --          | Sample              | =       | 24.4             |         | 26 - lb/d        |                          | =       | 3.54             |         | =                | 4.9            | 19 - mg/L                | 01/07 - Weekly           | CP - COMPOS              |           |
|       |  |                                    |          |             | Permit Req.         | <=      | 350 DAILY AV     |         | 26 - lb/d        |                          | <=      | 24 DAILY AV      |         | <=               | 51 DAILY MX    | 19 - mg/L                | 01/07 - Weekly           | CP - COMPOS              |           |
|       |  |                                    |          |             | Value NODI          |         |                  |         |                  |                          |         |                  |         |                  |                |                          |                          |                          |           |
| 01042 | Copper, total [as Cu]                    | 1 - Effluent Gross                 | 0        | --          | Sample              | =       | 0.05             |         | 26 - lb/d        |                          | =       | 0.0076           |         | =                | 0.01           | 19 - mg/L                | 01/07 - Weekly           | CP - COMPOS              |           |
|       |  |                                    |          |             | Permit Req.         |         | Req Mon DAILY AV |         | 26 - lb/d        |                          |         | Req Mon DAILY AV |         | Req Mon DAILY MX | 19 - mg/L      | 01/07 - Weekly           | CP - COMPOS              |                          |           |
|       |  |                                    |          |             | Value NODI          |         |                  |         |                  |                          |         |                  |         |                  |                |                          |                          |                          |           |
| 50050 | Flow, in conduit or thru treatment plant | 1 - Effluent Gross                 | 0        | --          | Sample              | =       | 27.371           | =       | 1.532            | 03 - MGD                 |         |                  |         |                  |                |                          | 99/99 - Continuous       | TM - TOTALZ              |           |
|       |  |                                    |          |             | Permit Req.         |         | Req Mon DAILY AV |         | Req Mon DAILY MX | 03 - MGD                 |         |                  |         |                  |                |                          | 99/99 - Continuous       | TM - TOTALZ              |           |
|       |  |                                    |          |             | Value NODI          |         |                  |         |                  |                          |         |                  |         |                  |                |                          |                          |                          |           |
| 50050 | Flow, in conduit or thru treatment plant | P - See Comments                   | 0        | --          | Sample              | =       |                  | =       | 1546.4           | 78 - gal/min             |         |                  |         |                  |                |                          | 99/99 - Continuous       | TM - TOTALZ              |           |
|       |  |                                    |          |             | Permit Req.         |         |                  | <=      | 2431 2HR PEAK    | 78 - gal/min             |         |                  |         |                  |                |                          | 99/99 - Continuous       | TM - TOTALZ              |           |
|       |  |                                    |          |             | Value NODI          |         |                  |         |                  |                          |         |                  |         |                  |                |                          |                          |                          |           |
| 50050 | Flow, in conduit or thru treatment plant | Y - Effluent Gross (Supplementary) | 0        | --          | Sample              | =       | 0.878            |         | 03 - MGD         |                          |         |                  |         |                  |                |                          | 99/99 - Continuous       | TM - TOTALZ              |           |
|       |  |                                    |          |             | Permit Req.         | <=      | 1.75 ANNL AVG    |         | 03 - MGD         |                          |         |                  |         |                  |                |                          | 99/99 - Continuous       | TM - TOTALZ              |           |
|       |  |                                    |          |             | Value NODI          |         |                  |         |                  |                          |         |                  |         |                  |                |                          |                          |                          |           |
| 51040 | E. coli                                  | 1 - Effluent Gross                 | 0        | --          | Sample              |         |                  |         |                  |                          | =       | 1.04             | =       | 2                | 3Z - CFU/100mL | 01/01 - Daily            | GR - GRAB                |                          |           |
|       |  |                                    |          |             | Permit Req.         |         |                  |         |                  |                          | <=      | 126 DAILY AV     | <=      | 399 DAILY MX     | 3Z - CFU/100mL | 01/01 - Daily            | GR - GRAB                |                          |           |
|       |  |                                    |          |             | Value NODI          |         |                  |         |                  |                          |         |                  |         |                  |                |                          |                          |                          |           |
| 80082 | BOD, carbonaceous [5 day, 20 C]          | 1 - Effluent Gross                 | 0        | --          | Sample              | =       | 16.33            |         | 26 - lb/d        |                          | =       | 2                | =       | 2                | 19 - mg/L      | 02/07 - Twice Every Week | CP - COMPOS              |                          |           |
|       |  |                                    |          |             | Permit Req.         | <=      | 73 DAILY AV      |         | 26 - lb/d        |                          | <=      | 5 DAILY AV       | <=      | 20 DAILY MX      | 19 - mg/L      | 02/07 - Twice Every Week | CP - COMPOS              |                          |           |
|       |  |                                    |          |             | Value NODI          |         |                  |         |                  |                          |         |                  |         |                  |                |                          |                          |                          |           |

**Submission Note**  
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**  
No errors.

**Comments**

**Attachments**

| Name             | Type | Size  |
|------------------|------|-------|
| MayDMRSheet.xlsx | xlsx | 19210 |

**Report Last Saved By**

**TROPHY CLUB MUD 1**

User: MMCMAHON@TCMUD.ORG  
Name: Mike McMahon  
E-Mail: mmcMahon@tcmud.org  
Date/Time: 2018-06-13 13:55 (Time Zone: -05:00)

**Report Last Signed By**

User: MMCMAHON@TCMUD.ORG  
Name: Mike McMahon  
E-Mail: mmcMahon@tcmud.org  
Date/Time: 2018-06-13 14:00 (Time Zone: -05:00)