

DMR Copy of Record

Permit			
Permit #:	TX0055735	Permittee:	TROPHY CLUB MUD 1
Major:	Yes	Permittee Address:	100 MUNICIPAL DRIVE TROPHY CLUB, TX 76262
Permitted Feature:	001 External Outfall	Discharge:	001-A DOMESTIC FACILITY - 001
Facility:		Facility Location:	TROPHY CLUB MUD 1 100 MUNICIPAL DRIVE ROANOKE, TX 76262

Report Dates & Status			
Monitoring Period:	From 05/01/18 to 05/31/18	DMR Due Date:	06/20/18
Status:	NetDMR Validated		

Considerations for Form Completion
SEE PAGE 2 OF PERMIT FOR ADDITIONAL REPORTING REQUIREMENTS.

Principal Executive Officer			
First Name:	Mike	Title:	Superintendent
Last Name:	McMahon	Telephone:	682-831-4689

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type				
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units		
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample	=	7				=	7					19 - mg/L	02/07 - Twice Every Week	GR - GRAB		
					Permit Req.	>=	6 MO MIN										19 - mg/L	02/07 - Twice Every Week	GR - GRAB		
					Value NODI																
00400	pH	1 - Effluent Gross	0	--	Sample	=	7.3				=	7.58					12 - SU	01/07 - Weekly	GR - GRAB		
					Permit Req.	>=	6 MINIMUM				<=	9 MAXIMUM					12 - SU	01/07 - Weekly	GR - GRAB		
					Value NODI																
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	8.5		26 - lb/d		=	1.2		=	1.4		19 - mg/L	02/07 - Twice Every Week	CP - COMPOS		
					Permit Req.	<=	175 DAILY AV		26 - lb/d		<=	12 DAILY AV		<=	40 DAILY MX		19 - mg/L	02/07 - Twice Every Week	CP - COMPOS		
					Value NODI																
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	=	2.06		26 - lb/d		=	0.4		=	0.48		19 - mg/L	02/07 - Twice Every Week	CP - COMPOS		
					Permit Req.	<=	15 DAILY AV		26 - lb/d		<=	1 DAILY AV		<=	10 DAILY MX		19 - mg/L	02/07 - Twice Every Week	CP - COMPOS		
					Value NODI																
00620	Nitrogen, nitrate total [as N]	1 - Effluent Gross	0	--	Sample	=	24.4		26 - lb/d		=	3.54		=	4.9		19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.	<=	350 DAILY AV		26 - lb/d		<=	24 DAILY AV		<=	51 DAILY MX		19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Value NODI																
01042	Copper, total [as Cu]	1 - Effluent Gross	0	--	Sample	=	0.05		26 - lb/d		=	0.0076		=	0.01		19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.		Req Mon DAILY AV		26 - lb/d			Req Mon DAILY AV			Req Mon DAILY MX		19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Value NODI																
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	27.371	=	1.532	03 - MGD								99/99 - Continuous	TM - TOTALZ		
					Permit Req.		Req Mon DAILY AV		Req Mon DAILY MX	03 - MGD										99/99 - Continuous	TM - TOTALZ
					Value NODI																
50050	Flow, in conduit or thru treatment plant	P - See Comments	0	--	Sample			=	1546.4	78 - gal/min								99/99 - Continuous	TM - TOTALZ		
					Permit Req.			<=	2431 2HR PEAK	78 - gal/min										99/99 - Continuous	TM - TOTALZ
					Value NODI																
50050	Flow, in conduit or thru treatment plant	Y - Effluent Gross (Supplementary)	0	--	Sample	=	0.878		03 - MGD									99/99 - Continuous	TM - TOTALZ		
					Permit Req.	<=	1.75 ANNL AVG		03 - MGD											99/99 - Continuous	TM - TOTALZ
					Value NODI																
51040	E. coli	1 - Effluent Gross	0	--	Sample						=	1.04		=	2		3Z - CFU/100mL	01/01 - Daily	GR - GRAB		
					Permit Req.						<=	126 DAILY AV		<=	399 DAILY MX		3Z - CFU/100mL	01/01 - Daily	GR - GRAB		
					Value NODI																
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	16.33		26 - lb/d		=	2		=	2		19 - mg/L	02/07 - Twice Every Week	CP - COMPOS		
					Permit Req.	<=	73 DAILY AV		26 - lb/d		<=	5 DAILY AV		<=	20 DAILY MX		19 - mg/L	02/07 - Twice Every Week	CP - COMPOS		
					Value NODI																

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments

Name	Type	Size
MayDMRSheet.xlsx	xlsx	19210

Report Last Saved By

TROPHY CLUB MUD 1

User: MMCMAHON@TCMUD.ORG
Name: Mike McMahon
E-Mail: mmcMahon@tcmud.org
Date/Time: 2018-06-13 13:55 (Time Zone: -05:00)

Report Last Signed By

User: MMCMAHON@TCMUD.ORG
Name: Mike McMahon
E-Mail: mmcMahon@tcmud.org
Date/Time: 2018-06-13 14:00 (Time Zone: -05:00)