

**DMR Copy of Record**

<b>Permit</b>			
Permit #:	TX0055735	Permittee:	TROPHY CLUB MUD 1
Major:	Yes	Permittee Address:	100 MUNICIPAL DRIVE TROPHY CLUB, TX 76262
Permitted Feature:	001 External Outfall	Discharge:	001-A DOMESTIC FACILITY - 001
Facility:		Facility Location:	TROPHY CLUB MUD 1 100 MUNICIPAL DRIVE ROANOKE, TX 76262

<b>Report Dates &amp; Status</b>			
Monitoring Period:	From 09/01/18 to 09/30/18	DMR Due Date:	10/20/18
Status:	NetDMR Validated		

**Considerations for Form Completion**  
SEE PAGE 2 OF PERMIT FOR ADDITIONAL REPORTING REQUIREMENTS.

<b>Principal Executive Officer</b>			
First Name:	Mike	Title:	Operations Manager
Last Name:	McMahon	Telephone:	682-831-4689

**No Data Indicator (NODI)**  
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type	
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample	=	6.88									19 - mg/L	02/07 - Twice Every Week	GR - GRAB
					Permit Req.	>=	6 MO MIN									19 - mg/L	02/07 - Twice Every Week	GR - GRAB
					Value NODI													
00400	pH	1 - Effluent Gross	0	--	Sample	=	7.27				=	7.74			12 - SU	01/07 - Weekly	GR - GRAB	
					Permit Req.	>=	6 MINIMUM			<=	9 MAXIMUM			12 - SU	01/07 - Weekly	GR - GRAB		
					Value NODI													
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	8.76		26 - lb/d		=	1.03		=	1.2	19 - mg/L	02/07 - Twice Every Week	CP - COMPOS
					Permit Req.	<=	175 DAILY AV		26 - lb/d		<=	12 DAILY AV		<=	40 DAILY MX	19 - mg/L	02/07 - Twice Every Week	CP - COMPOS
					Value NODI													
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	=	2.41		26 - lb/d		=	0.281		=	0.68	19 - mg/L	02/07 - Twice Every Week	CP - COMPOS
					Permit Req.	<=	15 DAILY AV		26 - lb/d		<=	1 DAILY AV		<=	10 DAILY MX	19 - mg/L	02/07 - Twice Every Week	CP - COMPOS
					Value NODI													
00620	Nitrogen, nitrate total [as N]	1 - Effluent Gross	0	--	Sample	=	39.9		26 - lb/d		=	4.632		=	5.2	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	350 DAILY AV		26 - lb/d		<=	24 DAILY AV		<=	51 DAILY MX	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Value NODI													
01042	Copper, total [as Cu]	1 - Effluent Gross	0	--	Sample	=	0.01		26 - lb/d		=	0.0115		=	0.012	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Permit Req.		Req Mon DAILY AV		26 - lb/d			Req Mon DAILY AV		Req Mon DAILY MX	19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Value NODI													
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	1.0056	=	1.349	03 - MGD							99/99 - Continuous	TM - TOTALZ
					Permit Req.		Req Mon DAILY AV		Req Mon DAILY MX	03 - MGD							99/99 - Continuous	TM - TOTALZ
					Value NODI													
50050	Flow, in conduit or thru treatment plant	P - See Comments	0	--	Sample			=	2417	78 - gal/min							99/99 - Continuous	TM - TOTALZ
					Permit Req.			<=	2431 2HR PEAK	78 - gal/min							99/99 - Continuous	TM - TOTALZ
					Value NODI													
50050	Flow, in conduit or thru treatment plant	Y - Effluent Gross (Supplementary)	0	--	Sample	=	0.915		03 - MGD								99/99 - Continuous	TM - TOTALZ
					Permit Req.	<=	1.75 ANNL AVG		03 - MGD								99/99 - Continuous	TM - TOTALZ
					Value NODI													
51040	E. coli	1 - Effluent Gross	0	--	Sample						=	1.03		=	3.1	3Z - CFU/100mL	01/01 - Daily	GR - GRAB
					Permit Req.						<=	126 DAILY AV		<=	399 DAILY MX	3Z - CFU/100mL	01/01 - Daily	GR - GRAB
					Value NODI													
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	17.1		26 - lb/d		=	2		=	2	19 - mg/L	02/07 - Twice Every Week	CP - COMPOS
					Permit Req.	<=	73 DAILY AV		26 - lb/d		<=	5 DAILY AV		<=	20 DAILY MX	19 - mg/L	02/07 - Twice Every Week	CP - COMPOS
					Value NODI													

**Submission Note**  
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**  
No errors.

**Comments**

**Attachments**

Name	Type	Size
Sept2018DMRsheet.xlsx	xlsx	16932

**Report Last Saved By**

**TROPHY CLUB MUD 1**

User: MMCMAHON@TCMUD.ORG  
Name: Mike McMahon  
E-Mail: mmcMahon@tcmud.org  
Date/Time: 2018-10-08 15:23 (Time Zone: -05:00)

**Report Last Signed By**

User: MMCMAHON@TCMUD.ORG  
Name: Mike McMahon  
E-Mail: mmcMahon@tcmud.org  
Date/Time: 2018-10-08 15:23 (Time Zone: -05:00)